



1. CHEEKWALL HEIGHT WILL VARY DEPENDING ON THE HEIGHT OF THE ABUTTING WALL. IT SHALL BE NO HIGHER THAN 2 COURSES ABOVE THE TOP OF THE FOUNDATION WALL.
2. CAULK SHOULD BE HIGH-QUALITY OIL-BASED CAULK (NON-SILICONE).
3. CANT TOP ROW OF BRICK TO SHED WATER TO FOOTWAY.

CITY OF PHILADELPHIA
DEPARTMENT OF STREETS

BRICK SIDEWALK AND CHEEK
WALL MULTIPLE WYTHE

DATE	12/08/14	SHEET 1 OF 1	SC0110B
REVISED	3/01/15		
APPROVED: V.L.F.			